

2014 Annual Compliance Audit

Water System: RURAL MUNICIPALITY OF MONTCALM (RED RIVER REGIONAL) - PWS

Code: 114.00

Water System Owner: RURAL MUNICIPALITY OF MONTCALM

Water System Operating Licence: PWS-08-243-01

Expiry Date: November 30, 2018

- 1) This report documents the Rural Municipality Of Montcalm (red River Regional) Public Water System compliance for the period from January 1 to December 31, 2014.
- 2) Addendum A to this report provides specific information on the non-compliance incidents identified in the summary below.
- 3) Other than the information provided in attached Addendum A, the water supplier has complied with *The Drinking Water Safety Act*, its supporting regulations, and the terms and conditions of the water system's current operating licence
- 4) This report is based on information submitted by the water supplier, agents of the water supplier, and / or the Province of Manitoba.

Summary of Non-Compliance Incidents:

- | |
|--|
| • Failure to Meet Bacteriological Requirements |
| • Failure to Meet Chemical Requirements |

Addendum A: Record of Non-Compliance

Water System: RURAL MUNICIPALITY OF MONTCALM (RED RIVER REGIONAL) - PWS

Report period: January 1, 2014 to December 31, 2014.

Enforcement Action Taken

| Date | Clause | Incident | Outcome |
|------|--------|---------------|---------|
| | | None reported | |

Disinfection Requirements

| Date | Samples | Incident | Outcome |
|------|---------|---------------|---------|
| | | None reported | |

Bacteriological Requirements

| Date | Samples | Incident | Outcome |
|------------|---------|--|---|
| 2014/09/23 | 1 | Failure to meet Bacteriological Standard: Total Coliform (TC) detected | Non-compliant Result Reported to the Office of Drinking Water |
| 2014/09/29 | 1 | Failure to meet Bacteriological Standard: Total Coliform (TC) detected | Non-compliant Result Reported to the Office of Drinking Water |

Microbial Requirements

| Date | Clause | Incident | Outcome |
|------|--------|---------------|---------|
| | | None reported | |

Turbidity Requirements

| Date | Samples | Incident | Outcome |
|------|---------|---------------|---------|
| | | None reported | |

Chemical Requirements

| Date | Clause | Incident | Outcome |
|------|------------|--|---|
| 2014 | OL Table 1 | Failure to meet the trihalomethane standard of less than or equal to 0.10 mg/L | Non-compliant Result Reported to the Office of Drinking Water |

Operational Requirements

| Date | Clause | Incident | Outcome |
|------|--------|---------------|---------|
| | | None reported | |